



KEYNOTES:

- 1 PROVIDE 3-POS. MOMENTARY SWITCH IN SINGLE GANG WALL OUTLETS FOR PROJECTION SCREEN. ROUTE CONDUIT AND REQUIRED CONDUCTORS TO PROJECTOR SCREEN JUNCTION BOX. COORDINATE WITH GENERAL CONTRACTOR FOR EQUIPMENT REQUIREMENTS AND TERMINATE AS REQUIRED.
- 2 PROVIDE JUNCTION BOX FOR OVERHEAD PROJECTOR. ROUTE EMT CONDUIT AND WIRING TO LOCATION FOR MOTORIZED SCREEN.
- 3 PROVIDE POWER ROUGH-IN FOR MOTORIZED SCREEN. CONNECT NOTED CIRCUIT.
- 4 SUMP PUMP SHALL BE FURNISHED & INSTALLED BY OTHERS. VERIFY EXACT LOCATION WITH CIVIL PLANS. E.C. SHALL VERIFY AND INSTALL ALL ELECTRICAL REQUIREMENTS. INSTALL RECEPTACLE IN ACCESSIBLE LOCATION AND AS HIGH AS POSSIBLE. "WILE IN USE" COVERPLATE SHALL BE UTILIZED.
- 5 DUPLEX SEWER PUMPS SHALL BE FURNISHED & INSTALLED BY OTHERS. VERIFY EXACT LOCATION WITH CIVIL PLANS. E.C. SHALL INSTALL ALL ELECTRICAL REQUIREMENTS INCLUDING POWER AND CONTROL CONDUIT AND WIRING.
- 6 IRRIGATION PUMP SHALL BE FURNISHED & INSTALLED BY OTHERS. VERIFY EXACT LOCATION WITH IRRIGATION PLANS. E.C. SHALL INSTALL ALL ELECTRICAL REQUIREMENTS.

1 POWER PLAN
 SCALE: 1/8" = 1'-0"

REFER TO LAUNDRY EQUIPMENT SCHEDULE ON SHEET E2.1 FOR EQUIPMENT SPECIFICATIONS AND CIRCUIT DESIGNATIONS.

Note: Wash. will be done in the shipping/receiving dock

1-1/2" CONDUIT TO EACH ATS WITH 6-#14 GAUGE RED CONDUCTORS NUMBERED FOR ATS/GEN CONTROL AND POWER CONDUIT PER RISER

ISSUE	DATE	DESCRIPTION
1.		
2.		
3.		